



Sonoma Valley Fire District

630 Second Street West, Sonoma CA 95476 - 707-996-2102

PLAN CHECK STANDARD COMMENTS

Addressing New and Existing Construction Unincorporated Sonoma County

Sec. 13-46. - Addresses for Buildings

All buildings shall be identified by an address issued by the director of permit and resource management. When issuing addresses, the director of permit and resource management shall use the following standards:

- All buildings other than accessory buildings shall be assigned separate addresses. Detached ADU's also require a separate address.
- Any other standards adopted by resolution or ordinance of the board of supervisors or by administrative regulation of the director of permit and resource management.

(Ord. No. 6318, § I, 8-11-2020)

Sec. 13-47. - Size of Letters, Numbers, and Symbols for Addresses - Numbers for one- and two-family dwellings

- Numbers shall be a minimum of **four inches (4") high with a minimum stroke width of one-half inch (0.5")**.
- Where access is by means of a private road and the building cannot be viewed from the public way, a monument, pole, or other sign or means shall be used to identify the structure.
- Illuminated address numbers are not required for existing buildings where approved; reflective numbers are to be installed.

(Ord. No. 6318, § I, 8-11-2020)

Sec. 13-48. - Installation, Location, and Visibility of Addresses

- All buildings shall have a permanently posted address, which shall be **placed on the building** and shall be plainly visible and legible from the road on which the address is located or the primary driveway. The numbers shall contrast with their background.
- All buildings shall have a permanently posted address, which shall be placed at each driveway entrance and shall be visible and legible from both directions of travel along the road on which the address is located.
- All address signs along one-way roads shall be visible from both the intended direction of travel and the opposite direction.
- Where multiple addresses are required at a single driveway, such addresses shall be mounted on a single approved post.

(Ord. No. 6318, § I, 8-11-2020)